

**NOMADIC™ RC MBR Mobile Sewage Treatment  
Residential Strength Wastewater in a C-Can  
General Specifications for Membrane Biological Reactor Models**

General

The NOMADIC™ RC MBR Membrane Biological Reactor model system shall consist of:

1. a modified cargo shipping container or multiple containers
2. an epoxy coated, multi-chamber steel tank,
3. Settling chamber
4. Membrane Biological Reactor wastewater treatment system,
5. a effluent discharge systems.

Cargo Container

The cargo shipping container shall be modified for man door access for maintenance personnel, service access hatches on the top of the container, and openings for fresh air inlet, sewage inlet, electrical conduit inlet and final effluent discharge.

The cargo container shall be fitted with steel skid plates, roll on / roll off bars and protective bollards. The container shall be re-painted in forest green colour or other colour as requested by the buyer.

The container shall be insulated and heated.

Operating Conditions

Each model number shall state the maximum number of persons that the system as designed to treat for the industrial / work camp.

Each person shall generate or contribute to not more than 227.3 litres of wastewater per day. The influent wastewater shall not have a combined sewage strength not exceeding a BOD5 of 250 mg/l, TSS of 250 mg/l, Fats, oils and greases of 35 mg/l and have a pH of 6.5 to 7.5 at all times.

Fats, oils and grease source control are solely the responsibility of the user of the NOMADIC™ RC MBR mobile wastewater treatment system to ensure that the level of as set down above is not exceeded.

Flow Equalization system to be supplied by others for the raw sewage wastewater entering into the NOMADIC™ RC MBR is recommended to be in accordance with the following:

- a. Volume per dose is not to exceed 7 ½ % of the total daily design flow
- b. Rest period per dose is not to be less than 15 minutes
- c. Volume per minute is not to exceed the allow limit of the ultra-violet light system

The effluent quality from the NOMADIC™ mobile wastewater treatment system shall have a BOD5 of < 5 mg/l, TSS of < 5 mg/l, Fecal Coliform of < 5 CFU/100 ml and a pH of 6.5 to 7.5

Multi-Chamber Steel Tank

The steel tank shall be coated inside and outside, including all internal steel pipe works, with an epoxy coating that has a ten (10) year warranty suitable for use in a sewage wastewater vessel.

Each of the steel tank's chambers shall have a volumetric working capacity in accordance with the requirements as determined by Pinnacle Environmental Technologies Inc. for the corresponding NOMADIC™ RC MBR model for the respective daily design flow rate.

Chambers used for aeration, settling or the MBR treatment shall be directly exhaust vented to the exterior of the cargo container. A chamber of a steel tank in each of the cargo containers shall hold the a discharge pump and, shall not be enclosed unless a sealed hatch cover is placed directly over the discharge pumps.

## NOMADIC™ RC MBR Mobile Wastewater Treatment System – General Specifications

Each chamber of the steel tank shall have a 100 mm diameter drain pipe connected to a brass knife/gate valve placed on the exterior of the steel tank complete with cam-lock fitting.

### Settling Chamber

The settling chamber shall have a volumetric capacity of not less than one day of the daily design sewage flow and shall be fitted with outlet baffle to flow by gravity into the MBR chamber.

The chamber shall be fitted with an inlet dispersal system and a baffled outlet. Outlet baffle shall be at least 1.8 metres distance from the inlet to flow, by gravity, the wastewater into the settling chamber.

### Membrane Biological Reactor (MBR)

The Membrane Biological Reactor shall be a submersed encased in a plastic liner.

The Membrane Biological Reactor shall be accredited under the National Standard of Canada system and the Standards Council of Canada or the American National Standards Institute as meeting either of the NSF International Standard 350, or the CAN/BNQ 3680.

The MBR shall be one of BioBarrier® as solely available from Pinnacle Environmental Technologies Inc. in Langley, British Columbia.

The MBR shall be supplied and installed by Pinnacle Environmental Technologies Inc. into the NOMADIC™ RC MBR system.

The MBR chamber shall have a volumetric capacity in accordance with the requirements as determined by Pinnacle Environmental Technologies Inc. for the corresponding daily design flow rate for the respective NOMADIC™ RC MBR systems.

### Effluent Discharge System

All effluent discharge pump system shall be an on-demand duplex alternating ½ HP, 2” solids handling pumps with liquid level sensors for pump on, pump off and high level alarm.

A pump controller shall be installed in accordance with the requirements of Pinnacle Environmental Technologies Inc. and shall have event recording capabilities to determine actual daily flow rates.

### Electrical

The NOMADIC™ RC MBR mobile wastewater treatment system shall be, at the Pinnacle factory, electrically wired by a Licensed Electrical Contractor who holds a “red seal” accreditation for Canada.

Electrical work to be conducted by qualified electrician at the location of the placement of the NOMADIC™ mobile treatment system shall be responsible for any electrical permits or compliance to local codes, bylaws or legislation in regards to connection and use of the NOMADIC™ RC MBR system

### Warranty

The MBR, all air blowers and controls are warranted against defects in material or workmanship for one (1) year from date of shipping from the factory. The steel tank is warranted against defects in material or workmanship for one (1) year from date of shipping from the factory.

The coating on the steel tank is warranted for ten (10) years from date of shipping from the factory.

Cargo Container is a one-time used container and has no warranty from original manufacturer.